



TEST REPORT

Technical Report: (6818)016-0146

January 24, 2018

Date Received: January 15, 2018

Page 1 of 4

Factory Company Name: Labonno Screen Print Ltd. (Unit-2)
Factory Address: Gorat, Zirabo, Ashulia, Savar, Dhaka, Bangladesh
Client: /
Initiated By: /
Sample Type: Grab Sample*
Sample Pick Up Date: January 15, 2018
Test Period: January 16, 2018 to January 24, 2018

Sample Description: Sample(s) received is/are stated to be:
I001) ETP Outlet Water

REMARK

This report shown the test result of the environment sample(s) of above factory which collected on specific date and time. The result(s) of this report shall not be used for any regulatory compliance purposes.

* The grab sampling is agreed with client.

**BUREAU VERITAS
CONSUMER PRODUCTS SERVICES (BANGLADESH) LTD.**

**M. NUR ALAM
SENIOR MANAGER
ANALYTICAL LABORATORY**

**Bureau Veritas
Consumer Products Services (BD) Ltd.**
Plot#130, DEPZ, Extension Area,
Ganakbari, Savar, Dhaka, Bangladesh.
Tel: 88-02-7789464-6, Fax: 88-02-7789462-3
E-mail: bvcpd.bd@bd.bureauveritas.com

This report is governed by, and incorporates by reference, the Conditions of Testing as posted at the date of issuance of this report at <http://www.cps.bureauveritas.com> and is intended for your exclusive use. Any copying or replication of this report to or for any other person or entity, or use of our name or trademark, is permitted only with our prior written permission. This report sets forth our findings solely with respect to the test samples identified herein. The results set forth in this report are not indicative or representative of the quality or characteristics of the lot from which a test sample was taken or any similar or identical product unless specifically and expressly noted. Our report includes all of the tests requested by you and the results thereof based upon the information that you provided to us. You have 60 days from date of issuance of this report to notify us of any material error or omission caused by our negligence; provided, however, that such notice shall be in writing and shall specifically address the issue you wish to raise. A failure to raise such issue within the prescribed time shall constitute your unqualified acceptance of the completeness of this report, the tests conducted and the correctness of the report contents.

The content of this PDF file is in accordance with the original issued reports for reference only.
This Test Report cannot be reproduced, except in full, without prior written permission of the company.

Photo of the Sample/ Sampling Location

I001) ETP Outlet Water



Executive Summary

Parameter	Conclusion
pH Value	See result in page 3
Total Suspended Solids (TSS)	
Chemical Oxygen Demand (COD)	See result in page 4
Biochemical Oxygen Demand (BOD ₅)	



Technical Report:

(6818)016-0146

January 24, 2018

Page 3 of 4

Test Result

pH Value

Test Method : With reference to APHA 4500-H⁺ B:2012 & U. S. EPA 150.2

Parameter	Unit	Result
Test Item(s)	-	I001
Temp. of sample	deg. C	23
pH value of sample	-	7.1
Conclusion	-	DATA

Note:

Temp. = Temperature

deg. C = degree Celsius (°C)

APHA = American Public Health Association Standard Methods for the Examination of Water and Wastewater

U. S. EPA = United States Environmental Protection Agency

Total Suspended Solids

Test Method : With reference to APHA 2540 D:2012

Tested Item(s)	Result	Unit	Conclusion
I001	12	mg/L	DATA

Note:

mg/L = milligram per liter

Detection Limit (mg/L) : 5

APHA = American Public Health Association Standard Methods for the Examination of Water and Wastewater



Technical Report:

(6818)016-0146

January 24, 2018

Page 4 of 4

Test Result

Chemical Oxygen Demand (COD)

Test Method : With reference to APHA 5220 B:2012 & U. S. EPA 410.3

Tested Item(s)	Result	Unit	Conclusion
I001	164	mg/L	DATA

Note:

mg/L = milligram per liter

Detection Limit (mg/L) : 2

APHA = American Public Health Association Standard Methods for the Examination of Water and Wastewater

U. S. EPA = United States Environmental Protection Agency

Biochemical Oxygen Demand (BOD₅)

Test Method : With reference to APHA 5210 B:2012

Tested Item(s)	Result	Unit	Conclusion
I001	28	mg/L	DATA

Note:

mg/L = milligram per liter

Detection Limit (mg/L) : 2

APHA = American Public Health Association Standard Methods for the Examination of Water and Wastewater

END